

FLOOR SLIP RESISTANCE TESTING CERTIFICATE



Testing Certificate Ref No:

AW/FS/1806002f

Client	The Millboard Company Ltd
Location	+Samples+
Date Tested	17 th June 2018
Pendulum Equipment Used	KSS Pendulum
Pendulum Serial No	ST13
Pendulum Calibrated	20th November 2017
Slider Type Used	96 slider
Slider Ser No(s) - Batch	96#79
Slider Date Expiry	14 th September 2018

The Pendulum was used in accordance with the United Kingdom Slip Resistance Group (UKSRG) guidelines for testing floors to ascertain the slip resistance to BS EN 14231. The tests were carried out under: -

- Wet Conditions (Using potable water to cover the whole test area and refreshed between tests).
- Dry & sunny conditions

Eight measurements were taken at each condition and in three different horizontal planes (0, 45 and 90 degrees) at each position. The first three measurements were discarded to allow checks for slider stabilisation. The median (average) of the remaining results were then calculated, as advocated by the UKSRG/Health & Safety Executive (HSE). The results for the floors tested are indicated in the table below:


The HSE / UKSRG has determined a minimum Pendulum Test Value reading of 36 must be obtained in all conditions (Dry, Wet, or Contaminated) and on a level surface for a floor to pass the test

Ref	Area / Room	Surface Type	Ambient Temp (deg C)	Mean (Average) Reading	Pass / Fail
1	Sample	Enhanced Grain Golden	20c	DRY 58	PASS
				WET 51	

Signed on behalf of FloorSlip Ltd:	<i>A. I. Wylie</i>	Name:	Andrew Wylie	Date:	17/06/18	Valid Until Date:	n/a
------------------------------------	--------------------	-------	--------------	-------	----------	-------------------	-----

This test certificate is not valid or original if the embossed company stamp is not present

FloorSlip Ltd - www.floorslip.co.uk
 e:mail - info@floorslip.co.uk
 Tel: 08719 152535 / 08713 155789



Registered Office - The Meridien, 4 Cophthall House, Coventry, CV1 2FL Company number: 07757686
 Please do NOT reply to this address as it is an unmonitored Address

