

# FLOOR SLIP RESISTANCE TESTING CERTIFICATE



Testing Certificate Ref No:

**AW/FS/1806002k**

Client	The Millboard Company Ltd
Location	+Samples+
Date Tested	17 <sup>th</sup> June 2018
Pendulum Equipment Used	KSS Pendulum
Pendulum Serial No	ST13
Pendulum Calibrated	20th November 2017
Slider Type Used	96 slider
Slider Ser No(s) - Batch	96#79
Slider Date Expiry	14 <sup>th</sup> September 2018

The Pendulum was used in accordance with the United Kingdom Slip Resistance Group (UKSRG) guidelines for testing floors to ascertain the slip resistance to BS EN 14231. The tests were carried out under: -

- Wet Conditions (Using potable water to cover the whole test area and refreshed between tests).
- Dry & sunny conditions

Eight measurements were taken at each condition and in three different horizontal planes (0, 45 and 90 degrees) at each position. The first three measurements were discarded to allow checks for slider stabilisation. The median (average) of the remaining results were then calculated, as advocated by the UKSRG/Health & Safety Executive (HSE). The results for the floors tested are indicated in the table below:


**The HSE / UKSRG has determined a minimum Pendulum Test Value reading of 36 must be obtained in all conditions (Dry, Wet, or Contaminated) and on a level surface for a floor to pass the test**

Ref	Area / Room	Surface Type	Ambient Temp (deg C)	Mean (Average) Reading	Pass / Fail
1	Sample	Weathered Oak Vintage	20c	<b>DRY 66</b>	<b>PASS</b>
				<b>WET 54</b>	

Signed on behalf of FloorSlip Ltd:	<i>A. I. Wylie</i>	Name:	Andrew Wylie	Date:	17/06/18	Valid Until Date:	n/a
------------------------------------	--------------------	-------	--------------	-------	----------	-------------------	-----

This test certificate is not valid or original if the embossed company stamp is not present

FloorSlip Ltd -. [www.floorslip.co.uk](http://www.floorslip.co.uk)  
 e:mail - [info@floorslip.co.uk](mailto:info@floorslip.co.uk)  
 Tel: 08719 152535 / 08713 155789



Registered Office - The Meridien, 4 Cophthall House, Coventry, CV1 2FL Company number: 07757686  
 Please do NOT reply to this address as it is an unmonitored Address

# FLOOR SLIP RESISTANCE TESTING CERTIFICATE

Testing Certificate Ref No: -



## Continuation Sheet - ONE

Ref	Area / Room	Floor Type	Ambient Temp (deg C)	Mean (Average) Reading	Pass / Fail

Continuation sheet – sheet 2 of 2 – Note – Use a New Floor Test Certificate Number where there are greater than 50 positions tested